

CAD 009 158 932  
2A

## Review Sheet:

### General Information

Inspection: unknown

Date of Inspection:

Name (Facility, Violator, School, Type: Desktop Inspection  
TCP): National Stel & Shipbuilding  
Company

Program: PCB

Site Street Address: Harbor Drive City: San Diego, State: CA Zip: 92186  
& 28th/ PO Box 85278 MS-22A

Contact Name/Complainant: County/District:

Contact Phone: Fax Number:

Inspector: unassigned

Inspector Number:

Inspection Number:

Inspector Sequence: ☐ 1 ☐ 2 ☐ 3 ☐ 4 ☐ 5

Investigation Type:

Investigation Reason Code:

SIC Code: SIC 2: SIC 3: SIC 4: SIC 5:

Facility Type:

Legislation: T (TSCA)

Region/State:

Misc.: EJ Area, Risky SIC

Subprogram:

Federal Facility: ☐ Yes ☐ No

Federal Action:

Self Confessor?

Self Confess Resolution:

Self Confess Resolution Date:

Asbestos

PCB

Lead Tips and Complaints

Parent Company Information

Archive Information

Case Review & Development

Date Referred to ORC:

Complaint Date:

CAFO Date:

Case Developer: Chris  
Rollins

Attorney: Unassigned

Docket Number:

Date Review Started:

Date Review Completed:

Action Warranted: ☐ Yes ☐ No

Settlement Amount:

Proposed Penalty:

or Case Number:

Type of Sep:

Sep?: ☐ Yes ☒ No

Sep Amount: 0

Reg. Violation: Non-Reporter Fiscal Year CC Filed: unknown FY CAFO Signed: unknown

Date CAFO Issued: (part 22 only)

FY CAFO Issued: (part 22 only)

FY NON Issued: unknown

NON Issued Date:

NON Closed Date:

**Notes**

**Notes:** A desktop inspection was reviewed after some information pertaining to PCB disposal was identified. This facility reported disposal of equipment. The equipment used to have PCBs > 50 ppm. But they have retrofilled these transformers multiple times. The latest date of retrofilling was in 2001. No violations were observed or documented because these transformers are not PCB regulated. I will close out this case in TED.

Status: ☐ Open ☒ Closed

Date Penalty Rec'd by Treasury:

Date Terms/Conditions met:

Date Closed: 10/13/2005